



1 RELOCATE EXISTING VTR'S TO BE AT MINIMUM 20' FROM ANY AIR INTAKE. EXISTING VS/VTR'S WILL HAVE TO BE REROUTED THRU 4TH FLOOR DUE TO COMPLETE DEMOLITION OF WALLS ON 4TH FLOOR. SUPPORT/PROTECT PIPING DURING DEMOLITION. ROUTE EXISTING VS PIPING INTO NEW WALL. VERIFY EXACT SIZE OF PIPING, COORDINATE PIPING SIZE WITH APPROPRIATE WALL THICKNESS. REPORT ANY ROUTING ISSUES TO ARCHITECT FOR COORDINATION.

01 SCALE: 1/8" = 1'-0"